

**Middle Georgia State University
Cochran Campus Water Quality Test Summary
June 2016**

The below table shows results of water quality tests conducted on the Cochran Campus in June 2016. These tests were conducted by the State of Georgia’s Environmental Protection Division as part of mandatory testing for water supplies for lead and copper concentrations.

The tests were conducted on 20 sampling locations on the Cochran Campus. **No locations indicated lead or copper concentrations exceeding the federally-defined Action Levels of 15 parts per billion (ppb) for lead or 1300 ppb for copper.**

For more detailed information about the water quality on the Cochran Campus, including:

- The official detailed results of the below tests,
- The 2015 Consumer Confidence Report, which includes information about the Cochran Campus’ water source, other test results, and the management of the Cochran Campus water system,
- Important reference information from the EPA about lead and other potential water contaminants,

please visit www.mga.edu/water.

Building	Copper concentration (ppb)	Lead concentration (ppb)
Sanford	250	2.2
Browning	78	2.5
Roberts	470	0
Russell	250	3.9
Dillard	1100	8.7
Harris	270	1.6
Talmadge	240	8.5
Peacock	180	0
Walker	100	0
Wiggs	270	0
Jackson	96	1.2
Ebenezer	430	1.3
Grace	240	4.2
Knights	130	1.6
Morris	480	1.9
Gateway	280	5.1
Whipple	95	3.7
Wellness	230	2.2
Regents	170	2.7
Georgia	550	0

If you have questions about the water supply on the Cochran Campus, please contact Interim Multi-Campus Director, Plant Operations, Tyler Warren, at 478-934-3008 or tyler.warren@mga.edu.